

Sponsor: Ladislav Schweiger Nanologix group s.r.o. tř. Budovatelů 2327/106 Most. 434 01 **CZECH REPUBLIC**

Bacterial Filtration Efficiency (BFE) and Differential Pressure (Delta P) Final Report

Test Article: NL Bacterial Filtration

Purchase Order: NANO0027

Study Number: 858973-S01

Study Received Date: 20 Nov 2015

Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 12

Summary: The BFE test is performed to determine the filtration efficiency by comparing the upstream bacterial control counts to downstream test article counts. A suspension of Staphylococcus aureus was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and challenge delivery. The challenge delivery is maintained at 1.7 - 2.7 x 10³ colony forming units (CFU) with a mean particle size (MPS) at $3.0 \ \mu m \pm 0.3 \ \mu m$. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. This procedure allows a reproducible bacterial challenge to be delivered to test materials. This test method complies with ASTM F2101-07 and EN 14683:2014, Annex B.

The Delta P test determines the breathability by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test was designed to comply with MIL-M-36954C, Section 4.4.1.2 and complies with EN 14683:2014, Annex C.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Either Side

BFE Area Tested: ~40 cm²

BFE Flow Rate: 28.3 Liters per minute (L/min)

Delta P Flow Rate: 8 L/min

Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and 21 ± 5 °C for a minimum of 4 hours.

Positive Control Average:

 2.0×10^{3} CFU

Negative Monitor Count:

<1 CFU

MPS:

3.0 µm



Janelle R. Bentz, M.S.

Study Completion Date



Results:

Test Article Number	Percent BFE (%)	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm²)
. 1	99.9	4.6	44.6
2	>99.9	4.9	48.2
3	>99.9	4.8	47.1
4	>99.9	5.0	49.3
5	>99.9	4.8	47.3

The filtration efficiency percentages were calculated using the following equation:

$$\% BFE = \frac{C-T}{C} \times 100$$

C = Positive control average
T = Plate count total recovered downstream of the test article
Note: The plate count total is available upon request

plp